



Ref. Certif. No.
SE-102286

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	DC-UPS
Name and address of the applicant	Bicker Elektronik GmbH Ludwig-Auer-Straße 23, 86609 Donauwörth, Germany
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	Input side: 24Vdc, max. 4.9A Output side: output voltage: normal mode: $V_{in} - 0,3V$ (full load), Backup: 23,5Vdc; output current: 4A max
Trademark (if any)	-
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	UPSI-2406DP1, UPSI-2406DP2
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 61010-1:2010+A1, IEC 61010-2-201:2017
As shown in the Test Report Ref. No. which forms part of this Certificate	2237854KAU-002, 2237854KAU-004

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

intertek

Signature:

Henrik Wikström

Date: 07 September, 2020